



# SIL

## Functional Safety Certificate

**No. 6L240122.AMA0C00**

Test Report / Technical Construction File no. AMA-20240115-3-SIL3-TCF

**Certificate's Holder:** Anhui Murphy Automation Instrument Co., Ltd.  
South side of Wei'er Road and west side of Jingqi Road in Tianchang Economic Development Zone, Anhui Province

**Product:** Level Instruments  
**Model(s):** LDUHZ-LB series, LDUHZ series, UHZ-LB series, UHZ series, LDUHZ-3CD series, LYUHZ series, LYRD series, MFUHZ series, MFRD series

**Standard:** Has been assessed per the relevant requirements of:  
IEC 61508:2010 Parts 1-7

And meets requirements providing a level of integrity to:  
Systematic Capability: SC 3(SIL 3 Capable)  
Random Capability: Type A Element  
SIL 2 @ HFT=0, SIL 3 @ HFT=1; Route 2<sub>H</sub>  
PFD<sub>AVG</sub> and Architecture Constraints must be verified each application

\* Application Restrictions:  
The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

\* Is suitable to be safety function according to the description and the configuration defined in Annex I

**Verification Mark:**



The Verification Mark can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way

**Remark:** This SIL Verification of Compliance has been issued on a voluntary basis. ECM confirms that a Test Report is existent for the above listed product(s) and found to meet the requirements of above standards for application in safety related system up to Safety Level of **SIL 3**. The unit must be properly designed into a Safety Instrument Function as per the requirements in the Safety Manual. The Verification Mark shown above can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way. In addition the Verification's Holder is NOT allowed to transfer the Verification to third parties. This certificate can be checked for validity at [www.entecerma.it](http://www.entecerma.it)

Date of issue 22 January 2024

Expiry date 21 January 2029

For online check:



Approver  
Ente Certificazione Macchine  
Legal Representative  
Luca Bedonni



Ente Certificazione Macchine

Via Cà Bella, 243 - 40053 Valsamoggia Loc. Castello di Serravalle (Bo) Italy  
☎ +39.0516705141 📠 +39.0516705156 ✉ info@entecerma.it 🌐 www.entecerma.it



# Annex I

## No. 6L240122.AMA0C00

Test Report / Technical Construction File no. AMA-20240115-3-SIL3-TCF

1. SC 3 (SIL 3 Capability):  
The product has met manufacturer design process requirements of Safety Integrity Level (SIL) 3. These are intended to achieve sufficient integrity against systematic errors of design by the manufacturer.
2. A Safety instrumented Function (SIF) designed with this product must not be used at a SIL level higher than stated.
3. Random Capability:  
The SIL limit imposed by the Architectural Constraints for each element.
4. IEC 61508 Failure Rates:

Failure Rate Data	Per 10 <sup>9</sup> Hours					
	Close On Trip				Open On Trip	
	Full Stroke		Tight Shutoff		Normal	Pvst
Normal	Pvst	Normal	Pvst			
Fail Dangerous Detected		301		412		188
Fail Dangerous Undetected	60	58	43	50	70	36

PVST: Partial Valve Stroke Test

5. SIL Verification:  
The Safety Integrity Level (SIL) of an entire Safety Instrumented Function (SIF) must be verified via a calculation of PFD<sub>AVG</sub> considering redundant architectures, proof test interval, proof test effectiveness, any automatic diagnostics, average repair time and the specific failure rates of all products included in the SIF. Each subsystem must be checked to assure compliance with minimum hardware fault tolerance (HFT) requirements.